

**Product Evaluation Report****Report No.:** FL-5016.3**Date:** July 31, 2023

Product Category	Sub Category	Manufacturer	Product Name
Windows	Fixed	Trinity Glass International 33615 1st Way South Federal Way, WA 98003 Phone: 253.875.7300	Transom / Fixed Lite "Impact"

**Scope:** This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Trinity Glass International based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

**Limitations:**

1. This product anchoring drawing has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection, this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and excludes Wind Zone 4 as defined in ASTM E 1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-5016.3 require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-5016.3 for size and design pressure limitations.

**Supporting Documents:**

- |  |  |   |  |
|--|--|---|--|
| 1. <b>Test Report No.</b><br>TEL 04253725<br>TEL 04253726  | <b>Test Standard</b><br>AAMA/WDMA/101/I.S.2/A440-17<br>ASTM E1886-13a/E1996-14a                      | <b>Testing Laboratory</b><br>Testing Evaluation Laboratories Inc.<br>Testing Evaluation Laboratories Inc. | <b>Signed by</b><br>V.K. Wright<br>V.K. Wright           |
| 2. <b>Miami-Dade NOA</b><br>21-0216.01   | <b>Materials</b><br>Saflex® PVB Interlayer (Eastman Chemical Company)                                |   |  |
| 3. <b>Drawing No.</b><br>No. FL-5016.3   | <b>Prepared by</b><br>RW Building Consultants, Inc. (#9813)  |   | <b>Signed &amp; Sealed by</b><br>Lyndon F. Schmidt, P.E. |
| 4. <b>Calculations</b><br>Anchoring<br>ASTM E 1300 Glass Load  | <b>Prepared by</b><br>RW Building Consultants, Inc. (#9813)<br>RW Building Consultants, Inc. (#9813) |   | <b>Signed &amp; Sealed by</b><br>Lyndon F. Schmidt, P.E. |
| 5. <b>Quality Assurance</b><br>Certificate of Participation issued by National Accreditation & Management Institute, Inc., certifying that Trinity Glass International is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. |  |   |  |

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409  
This item has been digitally signed and sealed by L. F. Schmidt on 8-01-23.  
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.  
**THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA**